

Form VI
Boiler Inspection Department
Government Of Jharkhand
CERTIFICATE FOR USE OF A BOILER
 ([Regulation 389])

Application Number: BRR25060600069	Boiler Registry No.: JH/9064
Boiler Rating : 107 meter square	Place and year of manufacture : Tiruchilapalli, Tamilnadu (2014)
Maximum Continuous Evaporation 3 Tones per Hour	Manufacturer name : M/S Veasons Energy System Pvt. Ltd.
Name of Owner: PRAVEEN GUPTA	Boiler Maker No: VBRB-252
Establishment name : SHRAVI AGRO MILLS PVT.LTD	Situation of Boiler Sharvi Rice Mill Pvt. Ltd. Nagari, Ranchi
Repairs(if any)	
Remarks Safety Valves set at pressure 10.25 & 10.50 Kg/cm² respectively.	Type of Boiler : HMST Boiler
Hydraulically Tested on 09/06/2025	to 16 Kg per square cm

I hereby certify that the above described boiler is permitted by me/the Boiler Inspector under the provisions of Section 7/8 of the Indian Boilers Act, No. V of 1923, to be worked at a maximum pressure of **10 Kg per square cm** for the period from **09/06/2025 to 8/6/2026**

The loading of the safety valve is not to exceed **10 Kg per square cm**

Total Fee Paid (in INR) : **4000.0**

Note:

1. This is a computer generated certificate, does not require any seal.
2. This certificate has been generated on the basis of the information given by the applicant and is valid for the purpose of this act only.

Competent Person / Boiler Inspector	Competent Person / Chief Boiler Inspector
--	--